



## REMOTE INTERFACE SPECIFICATIONS

### **ACC 062**

**Remote Hand Auto Switch Assembly** - To be wired in parallel with LOW MAIN and HIGH alarm relay contacts in refrigerant monitor. (PUSH ENGAGES NORMALLY OPEN CONTACTS, TWIST RELEASES)

**Electrical:**

Requires no power. Switch consists of three sets of NO contacts, rated at 5 amp 120 vac. Connect LOW NO terminal to LOW NO terminal in refrigerant monitor. Connect LOW COM terminal to LOW COM terminal in refrigerant monitor.

**Physical:**

7" h x 7" w x 4.5" d (nominal).

