



ALARM SPECIFICATIONS

ACC 027

24 vdc Power Supply for Low Voltage Alarms – AC power supply with terminals for ac power and two sets of terminals providing dedicated 24 volt dc to power remote strobe horn alarms. One power supply required for a monitor using 24vdc alarms. Not required for 120 vac alarms. *Mount the power supply near or inside the monitor. If mounted near the monitor, a suitably sized junction box is required, by others. Power from the same circuit as the monitor. Use relays inside the monitor to switch strobes and horns when in alarm.*

Electrical:

100-240 vac 50-60 hz Input

24 vdc Outputs

45 watt

Physical:

4.5" h x 2.5" w x 1.5" d