



REMOTE INTERFACE SPECIFICATIONS

ACC 062

Remote Hand Auto Switch Assembly - To be wired in parallel with LOW MAIN and HIGH alarm relay contacts in refrigerant monitor. (PUSH ENGAGES NORMALLY OPEN CONTACTS, TWIST RELEASES)

Electrical:

Requires no power. Switch consists of three sets of NO contacts, rated at 5 amp 120 vac. Connect LOW NO terminal to LOW NO terminal in refrigerant monitor. Connect LOW COM terminal to LOW COM terminal in refrigerant monitor.

Physical:

7" h x 7" w x 4.5" d (nominal).

